



JANE DEE HULL
GOVERNOR

OFFICE OF THE STATE FIRE MARSHAL



N. ERIC BORG
DIRECTOR

DUANE PELL
FIRE MARSHAL

99 EAST VIRGINIA, SUITE 100
PHOENIX, ARIZONA 85004
(602) 255-4964
(602) 255-4961 FAX

400 WEST CONGRESS, SUITE 121
TUCSON, ARIZONA 85701
(520) 628-6920
(520) 628-6930 FAX

Mr. Bill Duffy, Security Director
Superior Court /4th floor
201 W. Jefferson
Phoenix, Arizona 85003

RE: Fire Rat System

Dear Mr. Duffy;

I have completed a review of the material supplied concerning "Fire Rat", the Portable Fire Reporting System. This system appears to be very functional and would enhance safety and notification of an emergency in an area of demolition or reconstruction within your buildings.

While it would not replace the regular fire alarm system, it would certainly be useful in those areas we discussed. It would seem to be a good "tool" to assist in providing detection coverage.

If I may be of further assistance, please call on me.

Sincerely


Steve Alley
Assistant Fire Marshal

cc;chavez